

SHREE ATR LABORATORY**SERVICES (OPC) PRIVATE LIMITED**

Government of Maharashtra Approved Soil & Water Test Lab

Testing of Water | Foods | Drinks | Herbals | Soil | Chemicals | Fertilisers | Metals | Plastic

NABL Accredited Laboratory Certificate No. TC-14380

TEST REPORT

1.	Issue Date	:	23-03-2026
2.	Test Report No.	:	SATRL/25-26/03/326
3.	Name & Address of the Customer	:	SHRI.N.T.MUNDADA GLOBAL ENGLISH MEDIUM SCHOOL AMALNER, TA-AMALER, DIST-JALGAON
4.	Sealed/Unsealed	:	Sealed
5.	Date of Sample Receipt:	:	18-03-2026
6.	Lab ID	:	SATRL/25-26/03/326
7.	Sample Submitted By	:	(Lab Representative Mr. Pradip Chaudhari)
8.	Page No.	:	1 of 1

Sample Details

Nature of Sample : WATER

Sample Description : DRINKING WATER

Batch No/Mfg : NA


Sample Quantity : 1 lit

Analysis Start Date : 19-03-2026


Analysis End Date : 23-03-2026

Test Results

TEST RESULTS					
SR.NO	TEST PARAMETERS	RESULT	UNIT	IS 10500:2012 (RA 2023) REQUIREMENT	TEST METHOD
Chemical Testing					
1	Colour	< 1.00	Hazen Unit	Max 5	IS 3025 (P-4):2021
2	Odour	Agreeable	-	Agreeable	IS 3025 (P-5):2018 RA 2022
3	pH Value	7.12	-	6.50-8.50	IS 3025 (P-11):2022
4	Taste	Agreeable	-	Agreeable	IS 3025 (P-8):1984 RA 2022
5	Turbidity	< 0.1	NTU	Max 1 NTU	IS 3025 (P-10): 2023
6	Total Dissolved Solids (TDS)	180.00	mg/lit	Max 500	IS 3025 (P-16):2023
7	Calcium, as Ca	24.04	mg/lit	Max 75	IS 3025 (P-40):1991 RA 2019
8	Chloride, as Cl	17.72	mg/lit	Max 250	IS 3025 (P-32):1988 RA 2019
9	Fluorides, as F	0.12	mg/lit	Max 1	IS 3025 (P-60):2008 RA 2019
10	Free Residual Chlorine, as Cl ₂	BLQ	mg/lit	Max 0.2	IS 3025:1986 RA 2021
11	Iron, as Fe	0.03	mg/lit	Max 0.3	IS 3025 (P-2):2019 RA 2023
12	Magnesium, as Mg	5.84	mg/lit	Max 30	IS 3025 (P-46):1994 RA 2019
13	Nitrate, as NO ₃	3.00	mg/lit	Max 45	APHA 4500 B 22 rd Edn:2023
14	Sulphate, as SO ₄	3.00	mg/lit	Max 200	IS 3025 (P-24/Sec 1):2022
15	Total Alkalinity, as CaCO ₃	40.00	mg/lit	Max 200	IS 3025 (P-23):1986 RA 2019
16	Total Hardness, as CaCO ₃	120.00	mg/lit	Max 200	IS 3025 (P-21):2009 RA 2019
Biological Testing					
SR.NO	TEST PARAMETERS	RESULT	IS 10500:2012 (RA 2023) REQUIREMENT		TEST METHOD
1	<i>E.coli</i>	Absent	Absent/100 ml		IS 15185:2016 RA 2021
2	<i>Total coliform bacteria</i>	Absent	Absent/100 ml		IS 15185:2016 RA 2021
Remark: - Water is Potable as per IS 10500:2012 (RA 2023) specification & for above tested parameters. (Note-BLQ-Below Limit of Quantification, LOQ-Limit of Quantification)					


 Authorised by
 Microbiologist

Mr. Chandrakant Jadhav


 Reviewed & Authorised by

 Technical Manager
 Mr. A.G. Mahajan

Conditions of reporting : 1) Above result pertain only to the sample submitted, in full or part, shall not be published advertised, used for any legal action, unless prior permission has been secured 3) Samples will be retained by us for specified period (in the case of non perishable items only), unless specific instructions to the contrary are received 4) Sample was not done by ATR Lab. 5) All subject to Jalgaon Jurisdiction Only

Shop 32-35, Sureshdada Jain Vegetable Market, Ajintha Road, Jalgaon-425003(M.S)

9370007446 | 7448174467 | 9503631793

test@shreeatriabs.com | www.shreeatriabs.com